


NOTES:

- NEW WATER MAINS SHALL BE CONSTRUCTED USING EITHER:
  - HDPE SDR11 WITH FUSION WELDED FITTINGS
  - ASTM D2241 CL 160 PVC WITH MATCHING FITTINGS, AND EITHER JOINT RESTRAINTS OR THRUST BLOCKS.
- WHERE ACTIVE SERVICES EXIST, CONTRACTOR SHALL METER AND PLUMB TO EXISTING SUPPLY LINE AFTER NEW MAIN AND SERVICES ARE TESTED, DISINFECTED, AND FLUSHED TO THE SATISFACTION OF THE ENGINEER. A SATISFACTORY BACTERIOLOGICAL TEST IS REQUIRED PRIOR TO NEW MAIN BEING PUT INTO SERVICE.

INDICATES ACTIVE SERVICE WITH METER INSTALLED

INDICATES INACTIVE SERVICE NO METER INSTALLED

**MATCHLINE SEE SHEET C3.1**



CLIENT:  
 ONAMAC MAINTENANCE ASSOC.  
 P.O. BOX 1096  
 STANWOOD, WA. 98292  
 PH: (425) 244-6939  
 FX:  
 CONTACT: JOHN RICE  
 EMAIL: jonricecamano@gmail.com

WATER PLAN (WEST) FOR:

**ONAMAC WATER SYSTEM IMPROVEMENTS**

LAND SURVEYORS

**OLSON ENGINEERS**

ENGINEERING INC. 222 E. EVERGREEN, VANCOUVER, WA 98660

360-695-1385

COPYRIGHT 2022, OLSON ENGINEERING, INC.



CHANGES / REVISIONS	
DESCRIPTION:	DATE:

DESIGNED: SGB  
 DRAWN: TAS  
 CHECKED: CEM  
 DATE: MAY 2022  
 SCALE: H: 1"= 50'  
 V: N/A

ONAMAC WATER SYSTEM IMPROVEMENTS  
 JOB NO.: A10187.01.02

**SHEET**

**C3.0**

J:\cadd\A100000\A10187\Engineering\Final\Sheets\A10187.e\_Sheet\_Sol.dwg  
 PLOT\_STYLE



